


| LEGEND | TAG | NOTES |
|---|---|---|
| A. | FFV-1,FFV-2 | TWO(2) CLA-VAL 4" NORMALLY CLOSED FILL VALVE, CLA-VAL MODEL 136-03-BYC-KC-SS ACTUATED BY CONTROL PANEL |
| B. | JFV-1 | TWO(2) CLA-VAL 2" NORMALLY CLOSED FILL VALVE, CLA-VAL MODEL 136-01-AC-KC-SS ACTUATED BY CONTROL PANEL |
| C. | FLCP-1 | PLC BASED CONTROL PANEL WITH TOUCH SCREEN, COUGAR SYSTEMS MODEL 'ET11F3B1T1' - LEVEL CONTROL PANEL MUST USE INCHES AS THE UNIT OF MEASURE FOR TANK LEVEL, LEVEL TRANSDUCER, AND VALVE SETPOINTS. |
| D. | | CITY PRESSURE TRANSMITTER |
| E. | | PRESSURE GAUGE, WINTERS LF SERIES |
| F. | | SUBMERSIBLE PRESSURE TRANSDUCER |
| G. | | BACK UP HIGH LEVEL PROBE |
| H. | FBV-1 | MOTOR OPERATED FLOOD PROTECTION VALVE, ACTUATED BY CONTROL PANEL |

BLUE INDICATES "COORDINATE WITH OTHER DISCIPLINES"

INDICATES FIELD WIRING BY SYSTEM SUPPLIER

*ALL RELATED LOCAL CONTROL WIRE & CONDUIT BY SYSTEM SUPPLIER TO ENSURE A COMPLETE, COORDINATED AND FUNCTIONAL SYSTEM*

COUGAR☆USA
The Lone Star in Water Control
(832) 912-7000 | COUGARUSA.COM

Engineering Contact:
Michael Balboni
Direct: (713) 253-2320
Email: mbalboni@cougarusa.com

THIS DRAWING AND THE INFORMATION CONTAINED HEREIN IS THE EXCLUSIVE PROPERTY OF COUGAR SALES, INC. AND SHALL NOT BE REPRODUCED WITHOUT WRITTEN PERMISSION. THIS DOCUMENT IS ISSUED SOLELY AS A REFERENCE FILE. THIS DOCUMENT SHALL NOT BE USED FOR PERMITTING, BIDDING, OR CONSTRUCTION PURPOSES.

Fire Water Storage
Tank Fill Station
With Jockey

ISSUE FOR ENGINEER APPROVAL / SUBMITTAL

Sheet No.
P-1

C:\Users\tmorris\AppData\Local\Temp\AcePublish_91068\2_Detail - 4 Inch Fire Fill Station with Jockey.dwg - Friday, November 13, 2020 - 10:47 AM - tmorris